

TEST CERTIFICATE

Certificate Nr: EEA – 1700 – 0023

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 03.01.2017 in accordance with EN 1634-1:2014 standard for the specimen as described below:

“ RTK CD ” CHUTE DOOR

Single leaf

FIRE RESISTANCE CLASSIFICATION	
Direction: Opening away from the fire	E 120, EI ₂ 90
Direction: Opening into the fire	E120

Placed on the market by

ROTEK ENERJİ VE BACA SİS. SAN. VE TİC. LTD. ŞTİ.

Necip Fazıl Mah. Düzce Sok. No:59, Sultanbeyli – İSTANBUL/TURKEY


And Produced In the Factory

ROTEK ENERJİ VE BACA SİS. SAN. VE TİC. LTD. ŞTİ.

Necip Fazıl Mah. Düzce Sok. No:59, Sultanbeyli – İSTANBUL/TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report Nr. **EEA – 17– 006**.

This certificate is initially valid until 01st March 2018 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.



Ali BAYRAKTAR
Laboratuvar Müdürü

